



THIS ASSEMBLY USING THE 32/1000 PROFILE IN 0.7MM THICKNESS HAS BEEN IMPACT LOAD TESTED TO ACR(M)001:2019 (TEST FOR NON-FRAGILITY OF LARGE ELEMENT ROOFING ASSEMBLIES) AND ACHIEVED CLASS B NON-FRAGILITY RATING FOR SINGLE, DOUBLE AND MULTI-SPAN CONDITIONS.
ANY PART OF THE ASSEMBLY THAT IS UNFIXED OR PARTIALLY FIXED SHOULD BE CONSIDERED FRAGILE.
FIXING WASHER SIZE TO BE 16MM MINIMUM DIAMETER.



ROOF CONSTRUCTION DETAILS

Drawing Title
CL32 LINER NON-FRAGILE ASSEMBLY

Drawing Number	Revision
----------------	----------